

FIRE STOP

6624 5555 7 Centenary Drive, Goonellabah NSW 2480 Lic #268852C ABN: 38 164 334 356

office@firestop.net.au

PLEASE PAY BY

27/02/2024

AMOUNT

\$391.60

INVOICE DATE

13/02/2024

TAX INVOICE NO. 70694

Belle Property Byron Bay
Lennox Head,
39 Fletcher Street
Byron Bay NSW 2481

Site: 40 Lawson St, Byron Bay
Site Address: 40 Lawson Street
Byron Bay NSW 2481
Site Contact: Kim Komesarook - RB4 pick up
keys
Site Phone: 0493 299 690
Job No.: 52749
Order No.:
Job Name:

Description

Date of Inspection: 08/02/2024

Item	Quantity	Unit Price	Total
Exit & Emergency Lighting Test 6 Monthly	1.00	\$136.00	\$136.00
ABE 2.5kg Fire Extinguisher 6 Monthly Inspection	2.00	\$0.00	\$0.00
Smoke/Heat Alarm 6 Monthly Inspection & Test	5.00	\$0.00	\$0.00
Fire Blanket 6 Monthly Inspection	2.00	\$0.00	\$0.00
Scheduled Inspection	2.00	\$110.00	\$220.00
Site Fee	1.50 hrs	\$0.00	\$0.00

Thank you for your business.

Fire Stop is currently in the process of transitioning to a new computer system, you may receive invoices from both systems.
We appreciate your patience while we are going through this process.

Materials	\$356.00
Sub-Total ex GST	\$356.00
GST	\$35.60
Total inc GST	\$391.60
Amount Applied	\$0.00
Balance Due	\$391.60

This is a payment claim made under the Building and Construction Industry Security of Payment Act 1999 NSW

How To Pay

INVOICE NO. 70694



Direct Deposit

Bank **ANZ**
Acc. Name **FIRE STOP**
BSB **012715**
Acc. No. **284445262**



Mail

Detach this section and mail cheque to:

FIRE STOP
7 Centenary Drive
Goonellabah NSW 2480



Credit Card (MasterCard or Visa)

Pay Online firestop.simprosuite.com/payment/

Please call 02 6624 5555 to pay over the phone.

Please Reference: **70694**

FIRE STOP

6624 5555 7 Centenary Drive, Goonellabah NSW 2480 Lic #268852C ABN: 38 164 334 356

office@firestop.net.au

PLEASE PAY BY

27/02/2024

AMOUNT

\$391.60

INVOICE DATE

13/02/2024

TAX INVOICE NO. 70694

Asset Register - Exit Emergency Lighting Test FS

Log Book Location	Test Switch Location	Electrical Distribution Board Location	Note	Date	Pass / Fail
Msb		Front door	Unit 2 access required	08/02/2024	Pass

Asset Register - Smoke/Heat Alarm

Asset Number	Location	Type	Ceiling height	Date of Manuf.	Comments	Date	Pass / Fail
	Common: Main Entrance	Smoke Alarm 240V (10 Year Lithium)		New: 04/20		08/02/2024	Pass

Asset Register - Exit/Emergency Light

Asset Number	Type	Diffuser	Location	Comments	Model	Battery	Date	Pass / Fail
1	Exit Light	Running Man	Front door		LED Exit (Standard)*		08/02/2024	Pass
2	Emergency Light		Unit 2 stairs	New: 08/21 requires 10ft blue ladder	Spitfire LED Flush/m (Standard)*		08/02/2024	Pass

Asset Register - Scheduled Inspection

Comments	Date	Pass / Fail
Unit 1	08/02/2024	Pass

Asset Register - Smoke/Heat Alarm

Asset Number	Location	Type	Ceiling height	Date of Manuf.	Comments	Date	Pass / Fail
	Unit 1 - Entry	Smoke Alarm 240V (10 Year Lithium)		New: 01/23		08/02/2024	Pass
	Unit 1 - Hallway 1	Smoke Alarm 240V (10 Year Lithium)	8ft	New: 04/20		08/02/2024	Pass

Asset Register - Fire Blanket

Asset ID	Location	Type	Size	Date	Pass / Fail
	Unit 1		1.2 x 1.2	08/02/2024	Pass

Asset Register - ABE 2.5kg Extinguisher

Asset #	Make	Location	Last PT Date	PT Due Date	Comments	Date	Pass / Fail
1	Flamestop	Unit 1 - Kitchen	17/08/2023	01/08/2028		08/02/2024	Pass

Asset Register - Scheduled Inspection

Comments	Date	Pass / Fail
Unit 2	08/02/2024	Pass

Asset Register - Smoke/Heat Alarm

Asset Number	Location	Type	Ceiling height	Date of Manuf.	Comments	Date	Pass / Fail
	Unit 2 - Hallway	Smoke Alarm 240V (10 Year Lithium)		New: 04/20		08/02/2024	Pass
	Unit 2 - Main Bedroom	Smoke Alarm 240V (10 Year Lithium)		New: 04/20		08/02/2024	Pass

FIRE STOP

6624 5555 7 Centenary Drive, Goonellabah NSW 2480 Lic #268852C ABN: 38 164 334 356

office@firestop.net.au

PLEASE PAY BY	AMOUNT	INVOICE DATE
27/02/2024	\$391.60	13/02/2024

TAX INVOICE NO. 70694

Asset Register - ABE 2.5kg Extinguisher							
Asset #	Make	Location	Last PT Date	PT Due Date	Comments	Date	Pass / Fail
2	Flamestop	Unit 2 - Kitchen	22/02/2023	01/02/2028		08/02/2024	Pass

Asset Register - Fire Blanket					
Asset ID	Location	Type	Size	Date	Pass / Fail
	Unit 2		1.2 x 1.2	08/02/2024	Pass