



SITE PLAN INSET



WET LAND BOUNDARY

POOL LEGEND	
LT	INDICATES UNDERWATER LIGHT
SK	INDICATES SKIMMER BOX
RTP	INDICATES POOL RETURN (2 MIN. IF NOT SHOWN BULDER TO CONFIRM ON SITE)
HRV	INDICATES HYDROSTATIC RELIEF VALVE
- - -	INDICATES FALL OF POOL FLOOR
- - -	INDICATES FENCE LINE
1200	INDICATES POOL DEPTH
+1200	INDICATES APPROXIMATE HEIGHT OF POOL WALL OUT OF GROUND.
☐	INDICATES SAND FILTER LOCATED 300 MM FROM POOL FENCE, 1200 MM FROM TOP OF BOUNDARY POOL FENCE & ENCLOSED IN A SAND PROOF BOX IF REQUESTED BY COUNCIL.

NOTES

- P1 POOL BUILDER TO ENSURE ANY FOOTINGS OR ADJOINING STRUCTURES ARE NOT UNDERMINED BY POOL EXCAVATION. ANY UNDERPINNING REQUIRED SHALL BE DONE BEFORE EXCAVATION.
- P2 POOL WATER TO BE TREATED IN ACCORDANCE WITH AS 3683.
- P3 POOL AREA TO BE FENCED IN ACCORDANCE WITH AS 1926.1-2012 & POOL WATER RETICULATION SYSTEM TO COMPLY WITH AS 1926.3-2010.
- P4 EMPTY POOL BY DISCHARGING TO STORMWATER, OR SEWER (AS DIRECTED BY COUNCIL).
- P5 5/16 EARTHSTRAP TO REM. BESIDE SKIMMER AND WIRE TO HOUSE CIRCUIT EARTHING SYSTEM.
- P6 IF POOL FOUNDED ON FILL ENGINEERS TO BE CONSULTED FOR FIRM DESIGN.
- P7 ANY UNDERGROUND SERVICES SHOWN ON THIS PLAN ARE LOCATED IN GOOD FAITH FROM INFORMATION SUPPLIED TO US BY OTHERS. N.C.E. CARRIES NO RESPONSIBILITY FOR ACCURACY OF THE LOCATION OF SERVICES WHICH MUST BE LOCATED ON SITE BY OWNER.
- P8 IT IS THE BUILDER'S RESPONSIBILITY THAT WHEN POOL EXCAVATION EXCEEDS 1500 DEEP, PER TO ANY PERSON ARISING FROM THE COLLAPSE OF THE EXCAVATION / TRENCH OR ENGINEERING MUST BE MINIMIZED BY THE FOLLOWING, BUT NOT LIMITED TO: SHORING BY SHIELDING OR OTHER COMPARABLE MEANS (eg. BEHIND) BATTERING OR BENCHING.