



Ref: 790128

7 June 2022

Helen Tunks
HMC Environmental Consulting
132 Mafeking Road,
Goonengerry NSW 2482

Dear Helen

**132 Mafeking Road, Goonengerry NSW more particularly described as Lot 11 in DP 1202684
request to encroach on Essential Energy's easement**

We refer to your request to construct Effluent disposal trenches underground within Essential Energy's Easement.

Essential Energy has considered the details of your proposal and strictly based upon the documents submitted, Essential Energy consents to the encroachment of the Easement. Any amendments to the proposal will require Essential Energy's approval.

Prior to carrying out any works, a "Dial Before You Dig" enquiry must be undertaken in accordance with the requirements of *Part 5E (Protection of Underground Electricity Power Lines)* of the *Electricity Supply Act 1995* (NSW).

It is the responsibility of the person/s completing any works around powerlines to understand their safety responsibilities. SafeWork NSW (www.safework.nsw.gov.au) has publications that provide guidance when working close to electricity infrastructure. These include the *Code of Practice – Work near Overhead Power Lines/Underground Assets*.

Notwithstanding Essential Energy's approval to the encroachment any activities within the easement, or in proximity to Essential Energy's infrastructure, must be undertaken in accordance with the latest industry guideline currently known as *ISSC 20 Guideline for the Management of Activities within Electricity Easements and Close to Infrastructure*. A copy of this guideline can be located at www.resourcesandenergy.nsw.gov.au/__data/assets/pdf_file/0004/466816/ISSC-20-Electricity-Easements.pdf.

If you have any queries, please contact Adam Wauchope on telephone 0436336210 or via email LandR.encroachments@essentialenergy.com.au.

Yours sincerely

A handwritten signature in black ink that reads "Adam Wauchope".

Adam Wauchope
Land and Route Specialist